



FIELD & SAFETY INSPECTION CHECKLIST

VENTS/HOODS:

- BATHROOMS VENTILATED
- KITCHEN/HOOD/PROPER FILTER

SMOKE DETECTORS:

- ELECTRICAL/BATTERY TYPE
- BEDROOMS/HALLWAYS
- WAREHOUSE/STORAGE
- CLOTHES DEPARTMENT
- FIRE ALARM CERTIFICATION

ELECTRICAL PANELS:

- LABEL BREAKERS ACCORDINGLY
- PANEL COVERS
- 3 FT. SPACE CLEARANCES

EXPOSE WIRES:

- 7 FT. BELOW CEILING
- CAP ALL ELECTRICAL OUTLETS IN CHILDREN AREA(S) (IF INSPECTION IS FOR KINDERGARTEN & BELOW)
- SWITCHES/OUTLET COVER(S)
- SIZE OF ELECTRICAL WIRES
- COVER EXPOSED WIRE W/MOLDING

PROPANE GAS:

- METAL/COPPER PIPING
- 3 FT. HOSE ALLOQ FROM GAS TANK TO PIPE, 3 FT. HOSE FROM PIPE TO BURNER(S)
- SECURED GAS TANK(S)
- LEAK TEST CERTIFICATION
- PROPERLY SECURED

FIRE EXTINGUISHERS:

- FULL/EMPTY (INSPECTED)
- BRACKET MOUNT (4 INCHES FROM THE FLOOR)
- 2-3 LBS (ABC TYPE)
- CLASS K FOR RESTAURANT/KITCHEN

EGRESS:

- ENTRANCE & EXIT DOOR(S)
- EXIT SIGN(S)
- EXTERIOR LIGHT ABOVE EXIT DOOR OR ABOVE DOOR
- EMERGENCY LIGHT(S)